

Zakázka číslo :
Název : Objekt
Adresa : Prokopa Diviše 1605/5
Ústí nad Labem

Výpočtová venkovní teplota : -12°C
Charakteristické číslo budovy B : 12

Číslo místnosti	Název místnosti	ti [°C]	Plocha [m²]	Objem [m³]	Qp [W]	Qv [W]	Qz [W]	Qc [W]	Qr [W]
1.NP									
101	Kancelář	20	27.56	107.5	3616	981	0	4597	4004
102	Kavárna	20	27.56	107.5	2602	643	0	3245	2652
103	Kavárna	20	37.60	146.6	3337	1740	0	5077	4269
104	Kavárna	20	21.42	83.5	1834	643	0	2477	2018
105	Restaurace	20	10.00	39.0	1087	582	0	1669	1454
106	WC	18	3.36	13.1	0	71	0	120	120
107	WC	18	3.40	13.3	0	72	0	210	210
108	Denní místnost	20	8.00	31.2	1431	467	0	1899	1727
109	WC	18	2.00	7.8	295	174	0	469	431
110	WC	18	2.52	9.8	0	53	0	175	175
111	WC	18	1.92	7.5	0	41	0	120	120
112	WC	18	4.40	17.2	639	301	0	941	857
113	WC	18	3.15	12.3	508	67	0	574	515
114	Kancelář	20	16.17	63.1	2237	484	0	2721	2373
115	Chodba	18	8.93	34.8	860	440	0	1300	1131
116	Chodba	18	18.80	73.3	0	397	0	280	280
Celkem :			196.79	767.5	18446	7156	0	25874	22336
2.NP									
201	Kancelář	20	23.40	91.3	2017	986	0	3003	3003
202	Kancelář	20	19.76	77.1	1409	695	0	2104	1849
203	Kancelář	20	24.44	95.3	1118	704	0	1822	1822
204	Kancelář	20	37.90	147.8	3435	2173	0	5608	5608
205	Kancelář	20	21.93	85.5	1033	697	0	1730	1730
206	Kancelář	20	17.68	69.0	1298	664	0	1962	1862
207	Kuchyňka	20	12.71	49.6	1026	464	0	1491	1491
208	WC	18	0.99	3.9	0	21	0	85	85
209	Chodba	18	11.50	44.9	0	243	0	0	0
210	Sprcha	24	3.90	15.2	377	99	0	476	476
211	Kancelář	20	7.29	28.4	1023	367	0	1389	1389
212	Chodba	18	5.51	21.5	0	116	0	135	135
213	WC	18	3.15	12.3	453	67	0	520	520
214	Kancelář	20	16.17	63.1	1792	484	0	2276	2276
215	Chodba	18	8.93	34.8	690	456	0	1145	1145
Celkem :			215.26	839.5	15671	8236	0	23746	23391
3.NP									
301	Kancelář	20	23.85	88.2	2468	916	0	3384	3384
302	Kinosál	20	46.11	170.6	2290	1291	0	3581	3581
303	Kancelář	20	23.40	86.6	2635	1607	0	4243	4243

Zakázka číslo :

Název : Objekt

Adresa : Prokopa Diviše 1605/5

Ústí nad Labem

Výpočtová venkovní teplota : -12°C

Charakteristické číslo budovy B : 12

Číslo místnosti	Název místnosti	ti [°C]	Plocha [m²]	Objem [m³]	Qp [W]	Qv [W]	Qz [W]	Qc [W]	Qr [W]
304	Kancelář	20	14.30	52.9	879	684	0	1564	1564
305	Kancelář	20	22.79	84.3	1073	697	0	1770	1770
306	Kancelář	20	18.02	66.7	1163	685	0	1848	1848
307	Kancelář	20	12.71	47.0	980	464	0	1444	1444
308	WC	18	1.10	4.1	0	22	0	85	85
309	Chodba	18	11.60	42.9	0	232	0	0	0
310	Kuchyňka	20	3.75	13.9	0	80	0	140	140
311	Kancelář	20	7.56	28.0	1142	367	0	1509	1509
312	Chodba	18	5.51	20.4	0	110	0	115	115
313	WC	18	3.50	13.0	0	70	0	480	480
314	Kancelář	20	17.50	64.8	1918	484	0	2402	2402
315	Chodba	18	9.31	34.4	714	494	0	1208	1208
Celkem :			221.01	817.7	15262	8203	0	23773	23773

4.NP

401	Kancelář	20	23.85	88.2	2574	983	0	3556	3556
402	Kancelář	20	23.00	85.1	2453	867	0	3319	3319
403	Kancelář	20	24.91	92.2	1459	639	0	2097	2097
404	Kancelář	20	14.28	52.8	946	394	0	1340	1340
405	Kancelář	20	24.70	91.4	2455	1044	0	3499	3499
406	Kancelář	20	22.26	82.4	1448	676	0	2124	2124
407	Kancelář	20	18.55	68.6	1276	622	0	1898	1898
408	Kuchyňka	20	13.44	49.7	1540	468	0	2008	2008
409	WC	18	1.10	4.1	0	22	0	120	120
410	Chodba	18	6.00	22.2	0	120	0	150	150
411	Soc. zař.	22	3.38	12.5	371	77	0	448	448
412	Kancelář	20	7.29	27.0	1247	366	0	1613	1613
413	Chodba	18	15.50	57.4	0	311	0	230	230
414	WC	18	5.30	19.6	915	223	0	1138	1138
415	Kancelář	20	16.50	61.1	2174	402	0	2576	2576
416	Chodba	18	8.93	33.0	853	586	0	1438	1438
Celkem :			228.99	847.3	19711	7800	0	27554	27554

Celkem za zakázku :			862.05	3272.0	69090	31395	0	100947	97054
---------------------	--	--	--------	--------	-------	-------	---	--------	-------